

ANNEX 37E

RE-ENTRY BRIEF

COMPARTMENT SPECIALIST	NOTES
1. Latest temperature from TMS °C. All indications are the fire is extinguished. Indicate seat and spread of fire if any. 2. All Primary and Secondary mechanical and electrical isolations have been carried out and remain in force. 3. Brief compartment layout (diagram), position of equipment and location of walkways (do not brief route). 4. Hazards remaining within the compartment; HPA system and pressure vessels, residual fuel and lube oil, loose equipment. 5. Escape Routes. 6. Number of HPSW pumps available and HPSW pressure. 7. Brief outline of Smoke Clearance Plan.	
I/C FCP	
1. Team Tasks - identify all team members and their roles. 2. Location and seat of the fire. 3. General hazards: a. Trip/snagging. b. Integrity of deck plates and walkways. c. Spent firefighting equipment. d. Possible presence of free surface water. 4. Position and integrity of ladder, location of spare ladder. 5. Compartment lighting state, location of DC lighting. 6. Re-entry: a. Current location of FCP b. Point of re-entry. c. Hose routing. d. Location and content of foam dump. e. Use of Fixed Hatch Waterwall. (if applicable). f. Actions on discovering a casualty. g. Re-location of FCP. h. Re-location of smoke boundaries. i. Actions on forced retreat. j. Whistle policy. k. Confirm Team have understood brief.	
SENIOR OFFICERS BRIEF	
1. Reiterate compartment temperature °C and all indications are that the fire is extinguished. 2. Casualties - if none state none. 3. Morale - Hearts and Minds.	